



Dhr. Alberto Cardoso  
 Naban Carpets  
 Rua Doutor Manuel Melo  
 PT-3240-142 ANSIO  
 PORTUGAL

Your notice of	Your reference	our reference	date
		JW/1801	2009-02-25

## Certification Report Nr. 09/1801

### 1. Description of the flooring:

Product group: Woven broadloom carpet  
 80% wool / 20% polyamide 6.6  
 Jute/polyester

Total mass: 2250 g/m<sup>2</sup> - 2690 g/m<sup>2</sup>  
 Effective pile thickness: 7.8 mm

### 2. Executed tests:

European Fire classification in accordance with EN 13501-1 (2002)		
Class	EN ISO 11925-2 (15 s surface flame attack) or EN 14041 (2004)	EN ISO 9239-1 (test duration = 30 min)
C <sub>fl</sub>	E <sub>fl</sub>	heat flux ≥ 4,5 kW/m <sup>2</sup>

### 3. Conclusion:

Referring to the means of control and the test results, the before mentioned product group can be classified as follows:

loose laid on a non-combustible substrate

<b>C<sub>fl</sub> - s1</b>
----------------------------

This certification report runs to 2 pages and may be reproduced, as long as it is presented in its entire form, without written permission of Centexbel.

The results of the analysis cover the received samples. Centexbel is not responsible for the representativeness of the samples.

*Centexbel is recognized as notified body 0493 for the European Construction Products directive and the European directive for personal protective equipment*

**CENTEXBEL GENT**  
 Technologiepark 7  
 BE-9052 Zwijnaarde (Gent)  
 Tel. +32 9 220 41 51  
 Fax +32 9 220 49 55  
 e-mail gent@centexbel.be

**CENTEXBEL BRUSSELS**  
 Montoyerstraat 24-B2  
 BE-1000 Brussels  
 Tel. +32 2 287 08 30  
 Fax +32 2 230 68 15  
 e-mail brussel@centexbel.be

**CENTEXBEL VERVIERS**  
 Avenue du Parc 38  
 BE-4650 Herve (Chaineux)  
 Tel. +32 87 32 24 30  
 Fax +32 87 34 05 18  
 e-mail chaineux@centexbel.be

INDICHTING ERKENND BIJ TOEPASSING VAN DE BESLUITWET VAN 30 JUNI 1992 (M.B. 1992-10) OP AANVAARDING VAN DE TOEGANG TOT DE WETGEVING VAN 1987



**Addressee**  
Naban carpets

**our ref.**  
JW/1801

**date**  
2009-02-25

**page number**  
2


Related commercial names to this product group are:

- Ax Ecoflooring Ax27
- Ax Ecoflooring Ax32
- Ax Ecoflooring Ax35
- Ax Ecoflooring Ax39
- Ax Ecoflooring Ax43

The obtained classification is based on the next test reports:

- Centexbel: 67048 of 2009-02-20
- Centexbel: 67048/B of 2009-02-20

Certificate valid until 2014-02-20

i.o. 

Petra Wittevrongel  
certification coordinator